



Community and Environment

Drinking Water — Water System Design and Planning

Water Use Efficiency

## Annual Water Use Efficiency Performance Report Form

Please refer to the

Today's Date: 6/18/2019

General System Information

System Name:

CARLYON BEACH HOMEOWNERS 11159

System ID #: County: Your Name: Your Title:

THURSTON John Krenik

MaintananceLead shop@carlyonbeachhoa.com

Your Email Address: Your Phone Number:

(360) 866-8135

Meter Installation Information

Estimate the percentage of metered connections: More Than 75%

Current status of meter installation:

Last year's WUE report stated 92% of 607 total connections are metered (558). Since then we have installed 25 meters for a total of 583 as of 5/31/19. This leaves 24 meters left to install for the system.

Production, Authorized Consumption, and Distribution System Leakage Information

Reporting Year:

2018

12-Month WUE Reporting Period:

June 12, 2018 to May 31, 2019

Incomplete or missing data for the year?

No

If yes, explain:

| Distribution S | ivaram La | axana sunu | narv |
|----------------|-----------|------------|------|
|                |           |            |      |

Total Water Produced and Purchased (TP) - Annual Volume 29,447,500

26,570,350 Gallons Authorized Consumption (AC) - Annual Volume Distribution System Leakage - Annual Volume TP - AC

Distribution System Leakage - Percent DSL = [(TP - AC) / TP]  $\times$  100

2,877,150 Gallons 9.8 %

% 2016, 2017, 2018

3.5 3-Year Annual Average - Percent

## Goal-Setting Information

Date of most recent public forum:

May 17, 2011

Has goal been changed since last WUE report?

Demand Side Goal:

1) 10% or less water leakage. 2) Develop a plan to reduce leakage to under 10% if over. 3) Have all customers metered by the end of 2023. 4) Provide public education on conservation. 5) Set WUE goals every 6 years. 6) Continue source metering data. 7) Provide annual WUE report to DoH.

**Demand Side Goal Progress:** 

Installed 25 meters since October 2018 through May 2019. Repaired 7 water leaks in the same time frame. Set up a public meeting to set new goals by the board of trustees on June 25th, 2019. Informing customer's to conserve water in the newsletter. Increased the rate of pumping holding tanks from \$22 to \$24 in January 2018.

Additional Information:

<< Back

Please click 'Back' if you need to make changes.

Submit >>

Cancel

Contact Us

Agency Contacts Locations and Directions Consumer Assistance

**Email Consumer Assistance** 800-525-0127 TTY Users dial 711

Access Washington Contact our Web team Social Media

Find us on Facebook Follow @WA\_DeptofHealth

Notices

Privacy Notice Copyright Statement

See us on YouTube

**Publications** 

Health Education Resource Exchange **Publication List** 

**Alternate Format Requests** 

For people with disabilities, Web documents formats are available on request. To submit a please contact: Web Management Team.